

JAN 15 1954

25X1A9a

REUR 213 SUBJECT FLASHING. WE BELIEVE SEPARATION BY LEAD AS SPECIFIED IN PARA 21.8 WILL BE SATISFACTORY AND IF DEMANDED EXTRA JUSTIFIED IN VIEW OMISSION THIS WORK FROM GENERAL SPECS AND NON INCLUSION OF SEPARATION UNDER MECHANICAL SPECS. GROUNDING WOULD NOT HAVE DESIRED EFFECT.

15/2011Z