

		1520 8/23	0940 8/23	1530 8/23	1330	1400	1412	1545
Left Film Cont	1	73.4	74.1	72.0	72.2	72.7	72.6	72.5
Left Pinkish Cont	2	73.4	74.1	72.2	72.8	73.1	72.8	72.8
L Plenum out	3	72.0	72.5	71.7	72.8	72.9	72.9	72.9
L Pinkish out	4	73.6	74.5	71.8	71.7	72.2	72.1	72.3
R Pinkish	5	72.2	73.0	72.3	72.3	73.1	72.7	72.5
R Plenum out	6	73.4	74.0	73.3	73.8	74.0	74.0	74.1
Right Pinkish Cont	7	72.7	73.4	72.6	73.3	73.8	73.0	73.6
Film Cooling	8	72.6	73.0	72.4	73.2	73.2	73.2	73.4
Optical Bridge	9	74.1	74.4	74.7	76.0	75.7	75.7	75.0
Still Water In		42.8	46	45				
Clear Water Out		52.5	55	50				

Note: Vane
up + down
1 full degree
60 sec down
30 sec up
(72.1 & 73.4)

0825/27
1025/8/30

STATINTL

1	72.6	72.1
2	72.7	72.9
3	72.7	73.4
4	72.3	72.2
5	72.4 & 73	72.6
6	74.0	74.0
7	74.4	72.9
8	73.8	72.5
9	74.2	74.6
In	46	43
Out	51	49

NOTE: THESE READINGS
ARE D.B. Temp at
9 points in the
room taken by the
undersigned during the
period 8/23/71 to 8/30/71
at which time the
final alignment and
checkout of the HPSC
commenced per attached
memo -

STATINTL

MEMORANDUM FOR:

PMM
Please file attached
material in the High
Decision Store Computer
file

FORM NO. 101 REPLACES FORM 10-101
1 AUG 54 WHICH MAY BE USED. (47)

STAT