25X1

CENTRAL INTELLIGENCE AGENCY

INFORMATION REPORT

This material contains information affecting the National Defense of the United States within the meaning of the Espionage Laws, Title 18, U.S.C. Secs. 793 and 794, the transmission or revelation of which in any manner to an unauthorized person is prohibited by law.

	SECRET/M	PORN				- i
COUNTRY	East Germany/USSR		REPORT			
SUBJECT	Boor Quality of East German	TICCD	`ØATE DISTR	: .	14 July 1955	
	Transformers Exported to the	n GGU	NO. OF PAG	ES	1	-
DATE OF INFO.		' .	REQUIREME	NT		
PLACE ACQUIRED			REFERENCE	s		. 1
DATE ACQUIRED		This is	UNEVALU ation	IATED		
	THE SOURCE EVALUATIONS IN	THIS REPOR	T ARE DEFINITIV	E.		_

THE APPRAISAL OF CONTENT IS TENTATIVE.

(FOR KEY SEE REVERSE)

- 1. During 1951 and 1952 VKB Transformatorenwerk Oberschoeneweide (TRO)
 in Berlin-Oberschoeneweide, delivered six regulating transformers of
 100 MVA and 220 kV to the USSR. Within the next transpare however, they
 were returned from the USSR to TRO because they had become unserviceable after relatively short times of operation. Before the transformers were delivered to the USSR, they had been tested with 180 percent test voltage.
- 2. In 1952 TRO obtained another Soviet order for the delivery of two regulating transformers of 125 MVA and 220 kV. The order specified that these transformers were to be tested with 400 to 440 kV. One of these transformers was to be exhibited at the 1953 Leipzig fall fair, but this plan was abandoned when it turned out that the transformer did not pass the tests in the TRO test stands. From late 1953 on, TRO attempted to improve the two transformers scheduled for shipment to USSR. In mid-May 1955, the transformers were subjected to insulation tests with the test voltage mentioned. It turned out that neither transformer was able to operate under the specified conditions.

25X1



SECRET/NOFORN									
STATE #X ARMY #X NAVY 2		AEC	-	I 25X1 .					
	tion by "#"\			11/					