

CIA INTERNAL USE ONLY

19 March 1957

Suggestion No. 2699

Date of Suggestion: 12 December 1956

STATINTL

98-3- Guard,

A. Summary of the Suggestion:

Suggester proposed that the hinges on the gate at "M" Building be moved to the left side so that it will open from the right side.

*See attached*

B. Evaluation of the Concerned Office:

Chief, Administrative Staff/OL on 11 March 1957 stated the following:

"The proposal contained in subject Suggestion was investigated by the Assistant Safety Officer/OS and the Chief, Headquarters Section, SM&F Branch/OL.

"The investigation revealed that the hinges on the gate were free swinging; therefore, it would not be necessary to relocate them. However, the eyebolt which prevents the gate from swinging out can be turned to a horizontal position thus permitting a full swing of the gate in either direction. A tripping hazard can be eliminated by removing the horizontal pipe presently exposed under the gate.

"Contact has been made with the Public Buildings Service with respect to effecting changes mentioned above. Efforts are being made to have the work accomplished as quickly as possible.

"It is recommended that the Suggester be given a nominal cash award for an idea which will result in safer conditions for Agency personnel.


C. Recommendation of the Executive Secretary:

Approval. Award of \$10-\$25 based on intangible benefits (slight-limited).

10. w

CIA INTERNAL USE ONLY

PRESENT CYCLONE BARRICADE - FENCE  
M - Bldg - 26th ST L TOWER  
Approved For Release 2000/08/15 : CIA-RDP80-00832A000200070016-1



SUGGESTED MODIFICATION

